



Pin:260533474

ApplicationId:2605777534

Dated 12-May-2026

Certificate No:-PBIP-(FIRE) 2026/5790

Valid Till:- 11-May-2029 (3)year



Certified that the building on the name of GKB INTERNATIONAL SCHOOL, is situated at Guru Ki Ber Mattewal amritsar, owned by SRI GURU HARGOBIND SAHIB SEWA SOCIETY, is comprised of a total covered area of 1647 sq. mtrs and the height of the building is 7 meters including a total of 2 floor(s) and 0 basement(s).

This building is inspected by officer of Punjab Fire and Emergency Service and found complied with the firefighting system requirements of National Building Code, 2005 / 2016, Part-4. The site inspection was carried out in the presence of SHALLY MAHAJAN . This building / site is fit for occupancy Group Educational-(B) (this occupancy group is as per National Building Code, 2016 Part-4). This certificate is issued with the following conditions and this certificate is valid for 3 year.

Issued on 12-May-2026 at -Jandiala Guru

General Conditions:

1. Owner/Occupier is responsible to maintain the Fire Fighting System and Life Safety Systems in the working condition 24X7 at all the times.
2. No Alteration / addition / Change in Covered Area, Height of Building & Type of Occupancy is allowed..
3. Owner/Occupier shall ensure the periodic Fire Safety Training on Fire Prevention & Operationing of Fire Fighting Systems to among all the occupants and maintain records of the same. Owner/Occupier shall also ensure to organise Mock Drill Biannually and maintain the records of the same
4. Officer of Punjab Fire and Emergency Service is authorised to inspect your building as per the procedure defined in the Punjab Fire and Emergency Service Act, 2024 and in case of any deficiency or irregularity is found in the Fire Fighting System & Life Safety Systems, the officer of Punjab Fire and Emergency Service may initiate the appropriate action as deemed fit under the provisions of the Punjab Fire and Emergency Service Act, 2024, which may lead to imposing penalty or cancellation of Fire Safety Certificate etc.
5. Owner/Occupier shall apply for the renewal of fire safety certificate at least one month prior to expiry of this certificate.
6. In view of any Special Risks is Involved or life safety of the occupants, the approving Authority of this Fire Safety Certificate can issue Special Conditions separately through an official letter in continuation of this certificate.

* Above Details cannot be used as ownership proof.

* This is digitally created certificate, no signature is needed.



BHARTI FIRE SERVICE

Fire Equipment & Safety Equipment Co.
Dealing in ISI Mark Fire Extinguisher, Fire Hydrant System, Maintenance Contractor (AMC)
Fire Suppression System, On Floormg System, Safety Equipment's & Refilling & Servicing
Mob: 98150 94624, 62842 31041

HQ : 2nd Floor, R.204, Ramabal Ambedkar Nagar, (E) Highway, Ghatkopar (E), Mumbai-400075.

RO : VPO Bhaman, Teh Batala, Amritsar Road, Gurdaspur, Punjab, 143514

Ref. No. :- BFS/00387/2026-2027.

REFILLING CERTIFICATE

This is to certify that we have Supply of the Fire Extinguisher to:-

M/s : GKB INTERNATIONAL SCHOOL.
Add: Guru Ki Ber, Mattewal, Mehta Road,
Dist. Amritsar,
Punjab -143119.

Qty.	Discription/Type	Capacity	H.S.N	Refilling Date	Next Date	Remark
09-Nos	FIRE EXTINGUISHER ABC TYPE , REFILLING, SERVICING & INSTALLATION.	04-KG	381300	05/05/2026	04/05/2027	OK
01-Nos	FIRE EXTINGUISHER ABC TYPE, REFILLING, SERVICING & INSTALLATION.	02-KG	381300	05/05/2026	04/05/2027	OK

THE ABOVE FIRE EXTINGUISHERS ARE DEFENSIBLE FOR A PERIOD OF 01 YEARS FROM THE DATE OF BILL OF LADING NEXT TO BUILT-UPDETECT. THIS WARRANTEE WILL BECOME VOID IF THE FIRE EXTINGUISHERS ARE MISHANDLED, IMPROPER STORAGE.

